

ColdAIR Fact Sheet



EVAPORATIVE COOLING SYSTEMS

Prevention of Legionella

Evaporative coolers are unique water-using devices. They should not be confused with cooling towers or evaporative condensers, both of which have been verified as potential legionnaires' disease transmitters.

In contrast, Legionnaires' is not a problem with evaporative coolers.

- **Only water of drinkable quality supplied to the cooler**
This reduces the risk from contaminated supply
- **System design to maximise the evaporation of the water into the air without the water atomising**
This avoids any bacteria transmission in atomised water
- **Low air velocity over the evaporative filters**
This avoids formation of water droplets
- **Automatic control managing the water supply and discharge**
This ensures the drinkable quality of the water
- **Automatic cleaning cycle, replacing the complete reservoir of water**
This avoids any build up of stale water in the cooler
- **The water in the cooler operates at temperatures below the level for the formation of bacteria**
Normal operation of below 20°C ensures there is no potential for the growth of bacteria
- **The cooler automatically discharges the complete reservoir if power fails**
This ensures stagnant water does not remain in the cooler and thus prevents any potential for bacterial growth



An AmbiRad Group brand



AmbiRad Limited Fens Pool Avenue
Brierley Hill West Midlands DY5 1QA
United Kingdom



Telephone: 01384 489700
Facsimile: 01384 489707
Email: marketing@ambirad.co.uk
Website: www.ambirad.co.uk


ENERGY EFFICIENT HEATING SYSTEMS

AmbiRad is a registered trademark of AmbiRad Limited. Because of continuous product innovation, AmbiRad reserves the right to change product specification without due notice.